

CODIFIED ORDINANCES OF NUTTER FORT

PART FIFTEEN - FIRE PREVENTION CODE

ARTICLE 1511 Smoke Detectors

1511.01 Where required.

1511.99 Penalty.

1511.02 Enforcement provisions.

CROSS REFERENCES

Installation – see WVC 29-3-16a

1511.01 WHERE REQUIRED.

(a) Each new and existing structure used for multiple family or unrelated person's occupancy shall have installed in each living unit therein an approved fire detection product of combustion system. Such smoke detectors shall be capable of *sensing* visible or invisible particles of combustion and providing a suitable audible alarm thereof. They shall be installed by July 1, 1983, in the manner hereinafter provided. Failure to install smoke detectors in and where required by such date will subject property owners to penalties set forth in Section 1511.99.

(b) Each new and existing public building, used for the assembly of the public, either in dining, recreation, entertainment, or any building used to assemble the public not herein specified, shall have installed therein an approved fire detection product of a combustion system. Such smoke detectors shall be capable of *sensing* visible or invisible particles of combustion and providing a suitable audible alarm thereof. They shall be installed by July 1, 1983, in the manner hereinafter provided. Failure to install smoke detectors in and where required by such date will subject property owners to penalties set forth in Section 1511.99